

February 18, 2005

LENZYME INCORPORATED  
GLENN GAJESKI  
P.O. BOX 10356  
GREEN BAY WI 54307

Re: Description: CHEMICAL OR BIOCHEMICAL SEPTIC TANK ADDITIVE  
Manufacturer: LENZYME INCORPORATED  
Product Name: LENZYME WASTE DIGESTANT  
Model Number(s): NONE  
Product File No: 20040639

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2010.

This approval is contingent upon compliance with the following stipulation(s):

- If the formulation of this approved septic tank additive is modified, or additional assertions of function or performance are made, then this approval shall be rendered null and void, unless the change is submitted to this department for review and the approval reaffirmed.
- This product does not replace the need for a regular program of inspection and maintenance. This includes having the tank pumped out when the volume of sludge and/or scum occupies one-third of the tanks liquid capacity.
- Based on information supplied by the manufacturer and reviewed by this department, the approval for this product recognizes this septic tank additive will not adversely affect the user, the bacterial action in septic systems, the soil hydraulic conductivity in soil absorption areas, or groundwater quality, when used in accordance with the manufacturers instructions.

Based on information supplied by the manufacturer and reviewed by the department, this approval recognizes that this plumbing product will not adversely affect bacterial action in the private sewage system, soil hydraulic conductivity in the absorption areas, or groundwater quality beneath the system when used in accordance with the manufacturer's instructions.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

LENZYME INCORPORATED

Page 2

February 18, 2005

Sincerely,

Glen W. Schlueter  
Engineering Consultant-Plumbing Product Reviewer  
Bureau of Integrated Services  
Safety and Buildings Division  
Department of Commerce  
(608) 267-1401 Phone  
(608) 267-9566 Fax  
gschlueter@commerce.state.wi.us Email

GWS:gws